



APPROVALS®

## Certificate of Suitability

**Certificate No.:** SAA182148

**Certificate Holder:** ProJoy Electric Co., Ltd.  
XinTang Industrial Zone,  
North-city Street, PingJiang District,  
Suzhou 215000  
P.R. China

**Class Description:** Non-Declared  
**Product Description:** AC Switch-disconnector

**PROJOY**  
electric

**Brand Name:**  
**Model No.:** PEAS50-EI63-1N  
**Markings:** Ue=250V~

Ie=63A  
Ithe=63A  
Icw=0.76kA 1s  
Icm=1.5kA  
Ui=500V  
Uimp=4kV  
AC-22A  
IP66

**Standard:** AS/NZS 60947.3:2015  
AS/NZS 60947.1:2015

**Conditions:** Nil

**Certification Mark:** SAA182148 or RCM

**Date First Registered:** 10 August 2018  
**Date of Expiry:** 10 August 2023

For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd certifies that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)



Issued: 10-08-18 182148/1



APPROVALS®

## Certificate of Suitability

### \*Addendum\*

**Certificate No.:** SAA182148

**Date of Issue:** 10 August 2018

**Class Description:** Non-Declared

**Product Description:** AC Switch-disconnector

**Additional Models**

PEAS50-EI63-2N

PEAS50-EI63-3N

PEAS50-EI35-1N

PEAS50-EI35-2N

PEAS50-EI35-3N

PEAS50-EI20-1N

PEAS50-EI20-2N

PEAS50-EI20-3N

**Description**

Similar to PEAS50-EI63-1N except for 2-pole in lie of 1-pole and rated  $U_e=440V\sim$ .

Similar to PEAS50-EI63-1N except for 3-pole in lie of 1-pole and rated  $U_e=440V\sim$ .

Similar to PEAS50-EI63-1N except rated  $I_e=35A$ .

Similar to PEAS50-EI63-2N except rated  $I_e=35A$ .

Similar to PEAS50-EI63-3N except rated  $I_e=35A$ .

Similar to PEAS50-EI63-1N except rated  $I_e=20A$ .

Similar to PEAS50-EI63-2N except rated  $I_e=20A$ .

Similar to PEAS50-EI63-3N except rated  $I_e=20A$ .

For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd certifies that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)



Issued: 10-08-18 182148/2



10 August 2018

ProJoy Electric Co., Ltd.  
XinTang Industrial Zone,  
North-city Street, PingJiang District,  
Suzhou 215000  
P.R. China

C/- ICAL & TRADING CO

Dear Sir

**Certificate of Suitability – SAA182148**  
**AC Switch-disconnector**  
**Model No.: PEAS50-EI63-1N**

We are pleased to advise that your application for certification of the above electrical product has been successful.

Please ensure that you keep the enclosed Certificate in a safe place as it is your evidence that the product has been certified.

The certified product must now be marked with the SAA Number SAA182148 or may be marked with the Regulatory Compliance Mark (RCM). The RCM must be used in accordance with the conditions set out in the relevant parts of AS/NZS 4417.

Please note that if the electrical product is modified in any way or your company details change you are required to notify this office of the details of the modification. You can either download the required form from our web page or contact our office.

As part of our operational guidelines we are required to check that a certified product remains compliant during the term of the Certificate. At some stage during this term we may request a sample for evaluation.

If you need any further information or need to discuss this letter please don't hesitate to contact our office.

Yours sincerely

A handwritten signature in black ink, appearing to be 'J. K.', written over a horizontal line.

**For and on behalf of**  
**SAA Approvals Pty Ltd**

ABN 91 125 451 327

P. +61 7 3393 9455

F. +61 7 3393 9499

E. [info@saaapprovals.com.au](mailto:info@saaapprovals.com.au)

W. [www.saaapprovals.com.au](http://www.saaapprovals.com.au)

PO Box 189, Cannon Hill QLD 4170  
5/20 Rivergate Place, Murarrie QLD 4172