

ProJoy Electric Co., Ltd.  
XinTang Industrial Zone,  
North-city Street,  
PingJiang District, Suzhou  
215000  
P. R. China

Date : 10.07.2018  
Our ref. : HYS ZC10  
Your ref.: C.S.

**Ref : R TÜV-Mark Approval**

Type of Equipment : Installation Couplers  
Model Designation : See Certificate  
Certificate No. : R 50403268 0001  
Report No. : 50132225 001

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body

  
James Li

Enclosure

证书的详细资料请登陆[www.certipedia.com](http://www.certipedia.com)查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 50403268

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*  
C.S.

Unser Zeichen *Our Reference*  
ZC10-HYS-50132225 001

Ausstellungsdatum *Date of Issue*  
10.07.2018  
(day/mo/yr)

**Genehmigungsinhaber *License Holder***  
ProJoy Electric Co., Ltd.  
XinTang Industrial Zone,  
North-city Street,  
PingJiang District,  
Suzhou 215000  
P. R. China

Prüfzeichen *Test Mark*

Geprüft nach *Tested acc. to*  
EN 61535:2009+A1



Zertifiziertes Produkt (Geräteidentifikation)  
*Certified Product (Product Identification)*

Lizenzentgelte - Einheit  
*License Fee - Unit*

Connector (Installation Couplers)

Type Designation	: PEAC-F PEAC-PM-M PEAC-CM-M (PROJOY)	5
Rated Voltage	: AC 250V	
Rated Current	: 25A	
Number of Poles	: Two Poles with Earthing	
Degree of Protection	: IP68	
Protection Class	: For Class I Appliance	

The labelling requirements acc. to EU Directive 2001/95 have to be observed for distribution within the EEA.


5

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

**TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg**

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com  
Fax: +49 221 806-3935 http://www.tuv.com/safety



ProJoy Electric Co., Ltd.  
XinTang Industrial Zone,  
North-city Street,  
PingJiang District, Suzhou  
215000  
P. R. China

Date : 10.07.2018  
Our ref. : HYS ZC10  
Your ref.: C.S.

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Installation Couplers  
Model Designation : See Certificate  
Certificate No. : AN 50403271 0001  
Report No. : 50132225 001

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

  
James Li

Enclosure

证书的详细资料请登陆[www.certipedia.com](http://www.certipedia.com)查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询