

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50413221

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
C.S.

Unser Zeichen *Our Reference*
01-ZWC-50164777 001

Ausstellungsdatum *Date of Issue*
18.07.2018
(day/mo/yr)

Genehmigungsinhaber *License Holder*

ProJoy Electric Co., Ltd.
XinTang Industrial Zone,
North-city Street,
PingJiang District,
Suzhou 215000
P. R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60947-3:2009+A1+A2

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Switch-disconnector (Switch-disconnector)

Type Designation	: PEAS50-ELx-yN (x=20, 35 or 63) (y=1, 2 or 3) (PROJOY)	8
Utilization Category	: AC-22A	
Number of Pole	: 1P/2P/3P (y=1/2/3)	
Rated Operational Voltage (Ue)	: 250V(1P); 440V(2/3P)	
Rated Frequency	: AC 50/60Hz	
Rated Current (Ie)	: 20A/35A/63A(x=20/35/63)	
Conventional Enclosure Air Thermal Current (Ithe)	: 20A/35A/63A(x=20/35/63)	
Rated Insulation Voltage (Ui)	: 500V	
Rated Impulse Withstand Voltage	: 4,0kV	
Rated Short-time Withstand Current	: 0,76kA,1s	
Rated Short-circuit Making Capacity	: 1,5kA	
Pollution Degree	: 3	
Degree of Protection	: IP66	
Suitability for Isolation	: Yes	

8

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Jie Zhang