



Ref. Certif. No.

HU-003207

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Miniature Circuit Breaker

Name and address of the applicant

ProJoy Electric Co., Ltd.
XinTang Industrial Zone,
North-city Street, PingJiang District, Suzhou, 215000
Jiangsu, P.R. China

Name and address of the manufacturer

ProJoy Electric Co., Ltd.
XinTang Industrial Zone,
North-city Street, PingJiang District, Suzhou, 215000
Jiangsu, P.R. China

Name and address of the factory

Jiangsu Projoy Electric Co., LTD
NO.2266 Tai Yang Road,
Xiangcheng District, Suzhou, Jiangsu, P.R. China

Ratings and principal characteristics

Ue: 230/400V or 240/415V AC (1P); 400V or 415V AC (2/3/4P)
50/60Hz; In:1/3/6/10/16/20/25/32/40/50/63A; B/C/D-type;
Icn=10kA; Ics=7,5kA (PEM1-63); Icn=Ics=6kA (PEM2-63)

Trademark (if any)

PROJOY

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

PEM1-63 ; PEM2-63

Additional information (if necessary may also be reported on page 2)

Detailed information refer to test report NN20MVYS 001.

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015
See Test Report for National Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

NN20MVYS 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web:www.tuv.com

Date: 2020-10-13

Signature:

Gergely Bakos